

# Menesine ataskaita: 07.2018



UAB Fortum Klaipeda		sugeneruota: 1.08.2018				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.07	17.655	18.072	3.330	1.857	0.448	7.224
2.07	17.480	18.093	2.266	1.450	0.459	7.338
3.07	17.531	17.799	2.482	1.326	0.463	7.008
4.07	17.383	17.795	6.423	1.031	0.452	8.104
5.07	17.881	17.839	2.548	0.922	0.466	7.827
6.07	18.497	18.191	2.738	0.991	0.499	7.392
7.07	18.830	18.361	2.461	0.956	0.528	6.443
8.07	18.796	18.531	2.353	0.872	0.501	5.792
9.07	18.082	18.266	2.101	0.879	0.442	5.472
10.07	17.943	18.334	1.590	0.840	0.419	5.628
11.07	17.122	17.931	1.416	0.847	0.417	5.396
12.07	18.775	18.377	1.794	0.894	0.422	5.562
13.07	20.067	15.464	2.553	0.934	0.426	5.544
14.07	19.659	10.763	2.370	0.980	0.420	5.347
15.07	19.143	10.730	2.178	1.035	0.418	5.470
16.07	19.471	11.800	2.037	1.015	0.481	5.653
17.07	20.478	12.519	3.519	0.974	0.704	5.605
18.07	20.085	12.545	2.351	1.108	0.774	5.535
19.07	20.281	12.722	3.679	1.143	0.954	5.526
20.07	20.691	12.693	3.053	1.238	0.746	6.273
21.07	20.895	12.685	3.720	1.222	0.751	6.303
22.07	20.859	12.611	3.575	1.263	0.945	6.126
23.07	20.220	12.616	3.549	0.998	0.908	5.978
24.07	20.601	12.683	3.847	0.616	0.948	7.004
25.07	21.285	12.718	3.181	0.807	1.049	7.330
26.07	21.023	12.786	2.565	0.436	1.265	5.865
27.07	21.613	12.730	2.547	0.159	1.102	6.398
28.07	20.595	12.743	3.188	0.182	0.989	5.746
29.07	21.617	12.659	3.529	0.526	0.975	6.206
30.07	21.438	12.684	3.172	0.254	0.871	6.418
31.07	21.737	12.755	3.635	0.244	0.968	6.066
min	17.122	10.730	1.416	0.159	0.417	5.347
max	21.737	18.531	6.423	1.857	1.265	8.104
MMV	19.599	14.747	2.895	0.902	0.684	6.247
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 07.2018



	UAB Fortum Klaipeda						sugeneruota: 1.08.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.07	0.064	0.073	134.895	0.460	0.653	211515.70	
2.07	0.064	0.032	132.982	0.383	0.662	212384.95	
3.07	0.063	0.039	135.019	0.421	0.667	216505.14	
4.07	0.065	0.051	133.981	0.489	0.578	208824.26	
5.07	0.066	0.024	134.767	0.504	0.613	213889.00	
6.07	0.068	0.009	134.721	0.494	0.597	216546.70	
7.07	0.066	0.020	134.121	0.488	0.579	213963.98	
8.07	0.067	0.027	134.344	0.505	0.608	214925.54	
9.07	0.065	0.039	133.565	0.452	0.616	220746.45	
10.07	0.065	0.072	134.188	0.481	0.580	227586.00	
11.07	0.066	0.124	132.354	0.565	0.570	225755.79	
12.07	0.068	0.090	134.484	0.650	0.588	231006.18	
13.07	0.065	0.055	133.935	0.688	0.612	233248.98	
14.07	0.068	0.059	134.649	0.748	0.543	230087.57	
15.07	0.068	0.068	134.055	0.798	0.513	227594.35	
16.07	0.067	0.028	134.427	0.563	0.580	196957.62	
17.07	0.066	0.000	133.645	0.512	0.657	189838.18	
18.07	0.068	0.000	132.199	0.559	0.660	181551.39	
19.07	0.069	0.000	134.689	0.628	0.594	182306.12	
20.07	0.069	0.000	135.197	0.713	0.583	185139.51	
21.07	0.068	0.000	134.414	0.773	0.586	186179.93	
22.07	0.068	0.000	135.457	0.847	0.682	187762.64	
23.07	0.074	0.000	134.713	0.579	0.743	184715.26	
24.07	0.077	0.000	135.250	0.533	0.707	187741.73	
25.07	0.072	0.002	134.530	0.593	0.646	188441.85	
26.07	0.071	0.016	135.178	0.604	0.643	183481.35	
27.07	0.070	0.010	135.505	0.591	0.685	183168.57	
28.07	0.076	0.009	135.197	0.665	0.589	183726.92	
29.07	0.071	0.023	135.045	0.653	0.596	188566.95	
30.07	0.073	0.023	135.066	0.610	0.626	189082.00	
31.07	0.074	0.007	135.246	0.572	0.642	197810.23	
min	0.063	0.000	132.199	0.383	0.513	181551.39	
max	0.077	0.124	135.505	0.847	0.743	233248.98	
MMV	0.069	0.029	134.446	0.584	0.619	203259.84	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 07.2018



UAB Fortum Klaipeda		sugeneruota: 1.08.2018				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.07	136.831	1022.101	5.338	1013.934	1098.765	3.559
2.07	137.405	1016.684	5.407	1008.371	1094.743	2.518
3.07	138.472	1017.348	5.407	1008.162	1094.675	2.771
4.07	137.707	1017.671	5.481	1007.373	1065.789	7.198
5.07	138.455	1015.588	5.439	1006.167	1055.887	2.844
6.07	140.402	1016.278	5.307	1007.272	1068.056	3.042
7.07	141.760	1020.882	5.094	1011.472	1090.349	2.720
8.07	142.392	1023.400	5.033	1014.601	1112.573	2.623
9.07	140.771	1023.195	4.621	1013.351	1092.334	2.355
10.07	140.440	1024.401	4.142	1014.728	1075.312	1.766
11.07	139.068	1023.411	4.289	1013.362	1083.256	1.574
12.07	142.010	1019.640	4.057	1010.681	1074.625	1.996
13.07	144.740	1017.835	3.766	1009.109	1083.044	2.841
14.07	144.363	1018.643	3.858	1008.952	1087.314	2.634
15.07	143.083	1019.487	3.909	1009.581	1076.154	2.408
16.07	143.042	1018.837	5.301	1009.428	1092.982	2.272
17.07	145.016	1016.165	6.032	1006.438	1075.454	3.916
18.07	142.157	1015.871	6.361	1005.673	1082.907	2.610
19.07	140.885	1016.474	6.370	1006.816	1076.200	4.086
20.07	138.597	1016.855	6.416	1007.004	1087.116	3.395
21.07	138.813	1017.176	6.326	1007.576	1088.583	4.126
22.07	139.408	1018.939	6.287	1008.701	1074.007	3.970
23.07	137.688	1020.479	6.471	1010.766	1073.389	3.931
24.07	137.901	1021.061	6.480	1011.275	1070.298	4.277
25.07	138.748	1022.131	6.221	1012.039	1085.648	3.542
26.07	138.791	1024.801	6.286	1014.649	1091.359	2.853
27.07	139.072	1026.066	6.245	1016.078	1109.068	2.825
28.07	137.859	1021.226	6.424	1011.139	1079.885	3.549
29.07	139.069	1022.225	6.199	1011.797	1086.399	3.922
30.07	138.438	1026.726	6.269	1016.328	1088.774	3.514
31.07	139.592	1028.618	6.287	1017.879	1089.592	4.040
min	136.831	1015.588	3.766	1005.673	1055.887	1.574
max	145.016	1028.618	6.480	1017.879	1112.573	7.198
MMV	140.096	1020.330	5.518	1010.669	1084.017	3.215
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 07.2018



UAB Fortum Klaipeda		sugeneruota: 1.08.2018				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.07	2.321	D 12.040	0.107	168.619	0.657	0.933
2.07	1.812	D 12.229	0.106	166.227	0.547	0.946
3.07	1.658	D 11.679	0.105	168.773	0.601	0.953
4.07	1.289	D 13.507	0.109	167.476	0.698	0.826
5.07	1.153	D 13.045	0.111	168.459	0.720	0.876
6.07	1.238	D 12.320	0.114	168.401	0.706	0.852
7.07	1.195	D 10.739	0.110	167.651	0.698	0.827
8.07	1.090	9.654	0.112	167.931	0.722	0.868
9.07	1.099	9.121	0.109	166.956	0.646	0.881
10.07	1.051	9.379	0.108	167.735	0.688	0.829
11.07	1.059	8.993	0.110	165.442	0.807	0.815
12.07	1.117	9.271	0.113	168.105	0.929	0.840
13.07	1.168	9.240	0.109	167.419	0.983	0.875
14.07	1.225	8.911	0.113	168.311	1.069	0.775
15.07	1.294	9.117	0.114	167.569	1.140	0.733
16.07	1.269	9.421	0.112	168.033	0.804	0.828
17.07	1.217	9.341	0.110	167.056	0.732	0.938
18.07	1.385	9.226	0.114	165.248	0.799	0.943
19.07	1.428	9.210	0.116	168.361	0.898	0.848
20.07	1.547	D 10.454	0.115	168.996	1.019	0.833
21.07	1.527	D 10.505	0.114	168.017	1.104	0.837
22.07	1.579	D 10.211	0.114	169.322	1.210	0.974
23.07	1.247	9.964	0.123	168.391	0.827	1.062
24.07	0.771	D 11.673	0.129	169.063	0.761	1.010
25.07	1.009	D 12.217	0.121	168.162	0.848	0.922
26.07	0.545	9.775	0.118	168.972	0.863	0.918
27.07	0.199	D 10.664	0.117	169.382	0.844	0.978
28.07	0.227	9.577	0.127	168.997	0.951	0.841
29.07	0.657	D 10.343	0.119	168.806	0.934	0.852
30.07	0.318	D 10.696	0.121	168.832	0.871	0.894
31.07	0.305	D 10.111	0.124	169.057	0.817	0.917
min	0.199	8.911	0.105	165.248	0.547	0.733
max	2.321	D 13.507	0.129	169.382	1.210	1.062
MMV	1.127	10.412	0.114	168.058	0.835	0.885
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						