

Menesine ataskaita: 05.2019



	UAB Fortum Klaipeda						sugeneruota: 7.05.2019
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.05	17.476	9.133	3.274	0.351	1.757	6.004	
2.05	17.532	9.061	3.587	0.638	1.614	5.233	
3.05	15.982	9.161	4.342	0.278	1.297	5.500	
4.05	17.821	9.112	4.012	0.678	1.339	6.151	
5.05	18.103	9.134	3.994	0.382	1.481	5.848	
6.05	16.541	9.207	3.319	0.873	1.234	5.697	
min	15.982	9.061	3.274	0.278	1.234	5.233	
max	18.103	9.207	4.342	0.873	1.757	6.151	
MMV	17.245	9.134	3.756	0.532	1.454	5.739	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 05.2019



	UAB Fortum Klaipeda						sugeneruota: 7.05.2019
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.05	0.122	0.000	127.493	0.507	0.503	195003.04	
2.05	0.111	0.000	126.368	0.465	0.537	190669.45	
3.05	0.099	0.003	127.840	0.442	0.481	189049.25	
4.05	0.105	0.000	127.382	0.454	0.498	193876.29	
5.05	0.105	0.000	127.370	0.444	0.451	192982.20	
6.05	0.098	0.000	127.305	0.400	0.468	188356.60	
min	0.098	0.000	126.368	0.400	0.451	188356.60	
max	0.122	0.003	127.840	0.507	0.537	195003.04	
MMV	0.107	0.001	127.293	0.452	0.490	191656.10	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 05.2019



	UAB Fortum Klaipeda						sugeneruota: 7.05.2019
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h	
1.05	135.109	1015.160	7.439	1005.132	1038.488	3.650	
2.05	135.093	1000.363	7.355	991.679	1044.363	4.011	
3.05	131.249	1008.106	8.098	998.318	1020.626	4.835	
4.05	133.571	1012.448	7.611	1002.172	1059.418	4.473	
5.05	134.291	1020.081	7.303	1009.519	1034.040	4.433	
6.05	131.610	1023.072	7.936	1011.835	1048.554	3.673	
min	131.249	1000.363	7.303	991.679	1020.626	3.650	
max	135.109	1023.072	8.098	1011.835	1059.418	4.835	
MMV	133.487	1013.205	7.623	1003.110	1040.915	4.179	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 05.2019



	UAB Fortum Klaipeda						sugeneruota: 7.05.2019
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.05	0.439	D 10.007	0.203	159.367	0.725	0.719	
2.05	0.798	8.722	0.186	157.960	0.664	0.767	
3.05	0.347	9.167	0.165	159.800	0.631	0.687	
4.05	0.847	D 10.251	0.174	159.227	0.648	0.711	
5.05	0.478	9.747	0.174	159.213	0.635	0.644	
6.05	1.091	9.496	0.163	159.131	0.572	0.668	
min	0.347	8.722	0.163	157.960	0.572	0.644	
max	1.091	D 10.251	0.203	159.800	0.725	0.767	
MMV	0.665	9.565	0.178	159.116	0.646	0.699	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							