

Menesine ataskaita: 04.2020



	UAB Fortum Klaipeda sugeneruota: 27.04.2020					
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.04	9.666	7.637	3.396	0.000	0.671	0.043
2.04	8.279	7.655	6.784	0.000	0.352	0.019
3.04	7.761	7.652	8.773	0.000	0.588	0.000
4.04	7.853	7.741	6.454	0.000	0.480	0.003
5.04	7.875	7.738	8.929	0.000	0.476	0.002
6.04	9.349	7.682	5.338	0.000	0.942	0.009
7.04	10.308	7.642	3.348	0.000	0.707	0.006
8.04	9.727	7.689	5.340	0.000	0.489	0.001
9.04	9.388	7.634	3.569	0.000	0.520	0.005
10.04	8.115	7.736	3.341	0.000	0.290	0.012
11.04	8.423	7.747	2.957	0.000	0.324	0.006
12.04	9.603	7.718	4.447	0.004	0.420	0.004
13.04	10.289	7.616	8.904	0.000	0.710	0.020
14.04	8.031	7.699	7.560	0.000	0.433	0.011
15.04	7.893	7.747	2.726	0.000	0.446	0.002
16.04	9.177	7.666	4.643	0.000	0.545	0.004
17.04	7.904	7.678	4.065	0.000	0.364	0.002
18.04	8.183	7.674	2.622	0.000	0.354	0.003
19.04	8.737	7.739	2.501	0.000	0.362	0.014
20.04	9.472	7.692	3.804	0.000	0.420	0.004
21.04	10.061	7.670	2.465	0.000	0.546	0.002
22.04	11.366	7.537	2.285	0.000	0.738	0.014
23.04	12.902	7.430	7.195	0.000	0.859	0.010
24.04	12.866	7.366	3.654	0.017	0.823	0.010
25.04	9.747	7.494	5.752	0.000	0.486	0.003
26.04	10.796	7.516	7.152	0.000	0.505	0.007
min	7.761	7.366	2.285	0.000	0.290	0.000
max	12.902	7.747	8.929	0.017	0.942	0.043
MMV	9.374	7.646	4.926	0.001	0.532	0.008
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 04.2020



UAB Fortum Klaipeda		sugeneruota: 27.04.2020				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.04	0.042	0.020	127.755	0.000	0.277	213418.95
2.04	0.044	0.018	126.473	0.000	0.275	213725.54
3.04	0.051	0.092	127.960	0.000	0.184	214327.76
4.04	0.040	0.078	127.494	0.000	0.192	213692.25
5.04	0.047	0.162	128.260	0.000	0.169	214766.89
6.04	0.059	0.232	127.273	0.001	0.157	213079.82
7.04	0.068	0.234	126.998	0.001	0.181	211224.73
8.04	0.067	0.241	127.230	0.016	0.190	212673.57
9.04	0.074	0.291	127.808	0.006	0.258	210086.82
10.04	0.059	0.207	127.417	0.000	0.182	212069.98
11.04	0.047	0.151	127.408	0.000	0.186	212933.17
12.04	0.075	0.217	127.167	0.003	0.194	215087.93
13.04	0.077	0.211	127.247	0.017	0.171	234880.95
14.04	0.053	0.113	127.410	0.000	0.241	233585.87
15.04	0.060	0.124	127.432	0.000	0.148	230247.06
16.04	0.078	0.189	126.757	0.000	0.139	233450.45
17.04	0.044	0.105	127.556	0.000	0.209	229126.75
18.04	0.048	0.132	127.527	0.000	0.171	230204.31
19.04	0.050	0.120	127.178	0.000	0.250	233469.23
20.04	0.059	0.153	127.310	0.000	0.139	233846.89
21.04	0.069	0.161	127.569	0.000	0.252	229170.25
22.04	0.074	0.248	127.552	0.008	0.230	231918.23
23.04	0.093	0.283	127.384	0.040	0.189	239958.26
24.04	0.092	0.216	127.298	0.054	0.185	237953.26
25.04	0.058	0.115	127.439	0.000	0.235	232781.32
26.04	0.061	0.084	127.354	0.000	0.229	236651.35
min	0.040	0.018	126.473	0.000	0.139	210086.82
max	0.093	0.291	128.260	0.054	0.277	239958.26
MMV	0.061	0.161	127.395	0.006	0.201	224012.82
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 04.2020



	UAB Fortum Klaipeda			sugeneruota: 27.04.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.04	44.950	1021.793	6.865	1008.392	1022.287	3.811
2.04	42.320	1013.662	7.039	999.838	1007.367	7.582
3.04	41.186	1010.694	7.265	997.486	962.112	9.643
4.04	41.600	1030.718	6.986	1017.095	988.020	7.184
5.04	41.820	1044.967	6.884	1030.158	993.499	9.879
6.04	44.622	1045.046	7.131	1029.699	972.137	5.916
7.04	46.371	1038.372	6.857	1024.887	992.401	3.705
8.04	45.522	1040.966	6.936	1026.779	1027.597	5.851
9.04	44.350	1028.070	7.088	1014.639	1007.492	3.948
10.04	42.263	1033.997	6.947	1020.885	1026.438	3.643
11.04	42.993	1037.852	6.940	1024.600	1037.890	3.292
12.04	45.060	1028.171	6.790	1013.884	1033.653	4.999
13.04	45.725	1013.859	6.836	1001.373	1003.591	9.867
14.04	42.025	1020.259	6.974	1007.726	1026.576	8.327
15.04	41.569	1019.932	7.299	1006.613	1042.411	3.007
16.04	44.246	1017.861	6.974	1003.740	1047.518	5.183
17.04	41.662	1025.445	7.176	1011.869	1020.260	4.542
18.04	42.404	1030.011	7.107	1016.234	1029.567	2.928
19.04	43.574	1032.089	6.969	1018.546	1031.292	2.812
20.04	45.016	1038.494	7.031	1024.802	1024.681	4.244
21.04	46.201	1040.757	7.173	1026.509	1019.492	2.756
22.04	48.564	1040.057	7.110	1025.867	1046.564	2.526
23.04	50.779	1032.005	6.798	1018.340	970.166	7.889
24.04	50.934	1018.396	6.844	1004.591	1000.091	4.055
25.04	45.247	1014.632	6.982	1002.332	986.779	6.429
26.04	47.337	1019.739	6.907	1006.075	990.663	7.915
min	41.186	1010.694	6.790	997.486	962.112	2.526
max	50.934	1045.046	7.299	1030.158	1047.518	9.879
MMV	44.551	1028.379	6.996	1014.730	1011.944	5.460
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 04.2020



	UAB Fortum Klaipeda						sugeneruota: 27.04.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	0.000	0.071	0.071	159.694	0.000	0.396	
2.04	0.000	0.032	0.073	158.091	0.000	0.393	
3.04	0.000	0.000	0.086	159.950	0.000	0.263	
4.04	0.000	0.006	0.066	159.367	0.000	0.274	
5.04	0.000	0.003	0.078	160.326	0.000	0.241	
6.04	0.000	0.016	0.098	159.092	0.002	0.224	
7.04	0.000	0.010	0.114	158.748	0.002	0.258	
8.04	0.000	0.001	0.112	159.038	0.023	0.272	
9.04	0.000	0.008	0.124	159.760	0.009	0.369	
10.04	0.000	0.020	0.099	159.271	0.000	0.260	
11.04	0.000	0.010	0.079	159.260	0.000	0.266	
12.04	0.006	0.006	0.125	158.958	0.005	0.277	
13.04	0.000	0.034	0.128	159.059	0.024	0.245	
14.04	0.000	0.018	0.088	159.262	0.000	0.344	
15.04	0.000	0.004	0.100	159.290	0.000	0.211	
16.04	0.000	0.006	0.130	158.447	0.000	0.198	
17.04	0.000	0.003	0.073	159.445	0.000	0.298	
18.04	0.000	0.005	0.080	159.409	0.000	0.245	
19.04	0.000	0.023	0.084	158.973	0.000	0.357	
20.04	0.000	0.007	0.098	159.137	0.000	0.198	
21.04	0.000	0.003	0.115	159.461	0.000	0.361	
22.04	0.000	0.023	0.124	159.440	0.012	0.328	
23.04	0.000	0.016	0.155	159.230	0.057	0.270	
24.04	0.021	0.016	0.154	159.122	0.077	0.265	
25.04	0.000	0.005	0.097	159.299	0.000	0.336	
26.04	0.000	0.011	0.101	159.192	0.000	0.328	
min	0.000	0.000	0.066	158.091	0.000	0.198	
max	0.021	0.071	0.155	160.326	0.077	0.396	
MMV	0.001	0.014	0.102	159.243	0.008	0.288	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							