

# Menesine ataskaita: 05.2013



UBA Fortum Klaipeda		sugeneruota: 2.07.2013				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.05	17.265	9.583	8.436	18.701	0.781	6.786
2.05	17.599	9.840	7.450	19.959	1.371	6.370
3.05	17.724	9.839	7.651	14.787	0.981	5.736
4.05	18.524	9.689	7.712	4.862	0.694	5.079
5.05	18.342	9.760	7.536	24.515	0.552	6.919
6.05	18.547	9.993	7.662	12.489	0.731	6.890
7.05	19.120	10.015	6.821	2.583	0.759	5.657
8.05	18.912	9.881	6.601	5.576	1.891	5.297
9.05	D 2877.802	9.548	6.503	3.711	2.969	4.044
10.05	19.568	10.278	6.541	1.006	2.813	4.034
11.05	19.419	10.500	6.075	0.600	3.016	4.335
12.05	18.888	10.327	6.574	1.611	1.354	6.846
13.05	18.990	10.696	6.008	1.812	2.226	6.592
14.05	19.223	10.882	5.582	1.742	3.962	6.895
15.05	18.683	10.111	5.680	2.494	3.868	7.114
16.05	18.554	10.278	5.619	2.640	4.472	5.683
17.05	18.822	10.259	4.745	9.021	3.649	6.922
18.05	18.502	10.143	4.171	9.643	1.980	7.995
19.05	18.227	9.843	4.278	9.793	2.456	D 8.269
20.05	18.396	9.645	4.717	4.912	1.411	D 9.512
21.05	18.412	9.893	5.044	10.433	1.971	D 10.353
22.05	18.035	9.828	4.580	4.902	1.272	4.258
23.05	19.054	10.208	4.864	2.925	1.100	3.298
24.05	21.339	10.321	4.958	0.081	0.614	0.375
25.05	20.137	9.402	4.901	0.028	0.613	0.452
26.05	19.357	9.228	4.785	1.446	0.614	0.513
27.05	19.489	9.584	4.847	0.840	0.577	0.471
28.05	18.761	9.563	5.593	2.697	0.723	3.554
29.05	18.558	9.534	6.327	2.459	0.675	3.887
30.05	18.162	9.579	6.291	5.371	0.727	5.243
31.05	20.232	10.114	4.933	0.330	0.545	0.399
min	17.265	9.228	4.171	0.028	0.545	0.375
max	D 2877.802	10.882	8.436	24.515	4.472	D 10.353
MMV	111.053	9.948	5.919	5.938	1.655	5.165
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 05.2013



	UBA Fortum Klaipeda sugeneruota: 2.07.2013					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	m3/h
1.05	0.001	0.000	117.570	0.911	0.105	329118.90
2.05	0.008	0.000	124.028	0.934	0.134	310065.78
3.05	0.003	0.000	135.837	1.069	0.117	294914.56
4.05	0.005	0.000	138.516	1.305	0.131	290600.78
5.05	0.019	0.000	137.216	1.271	0.147	290466.53
6.05	0.027	0.000	142.917	1.301	0.150	290654.34
7.05	0.022	0.000	131.856	1.463	0.169	298381.59
8.05	0.013	0.000	109.427	1.324	0.138	286167.46
9.05	0.026	0.000	111.991	1.463	0.157	266196.06
10.05	0.042	0.000	110.865	1.442	0.179	278528.59
11.05	0.037	0.000	113.963	1.457	0.107	271351.53
12.05	0.092	0.000	116.525	1.411	0.162	280415.00
13.05	0.064	0.000	99.130	1.337	0.127	276140.37
14.05	0.060	0.000	85.747	1.264	0.135	272119.90
15.05	0.057	0.000	99.568	1.386	0.138	275719.21
16.05	0.040	0.000	96.139	1.518	0.129	277939.90
17.05	0.045	0.000	87.944	1.605	0.114	241912.06
18.05	0.134	0.000	88.903	1.619	0.134	210387.89
19.05	0.118	0.000	93.887	1.615	0.107	205888.73
20.05	0.135	0.000	96.442	1.660	0.123	206768.79
21.05	0.132	0.000	101.738	1.724	0.191	210558.81
22.05	0.112	0.000	91.943	1.386	0.284	189481.70
23.05	0.204	0.000	101.493	1.550	0.310	214757.89
24.05	0.317	0.002	109.162	1.701	0.437	204603.37
25.05	0.276	0.000	105.077	1.543	0.556	217088.79
26.05	0.273	0.000	132.828	1.688	0.611	207413.07
27.05	0.403	0.000	129.015	1.843	0.725	219334.98
28.05	0.309	0.000	109.136	1.710	0.513	258194.70
29.05	0.275	0.000	124.745	1.867	0.483	262811.25
30.05	0.274	0.000	117.118	1.906	0.483	271069.65
31.05	0.434	0.000	125.597	1.745	0.806	225694.25
min	0.001	0.000	85.747	0.911	0.105	189481.70
max	0.434	0.002	142.917	1.906	0.806	329118.90
MMV	0.128	0.000	112.458	1.485	0.261	255959.46
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 05.2013



UBA Fortum Klaipeda		sugeneruota: 2.07.2013				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc		
Diena	°C	mbar	Vol%	mbar		
1.05	139.864	1019.460	7.564	1023.207		
2.05	141.143	1018.533	7.210	1020.972		
3.05	140.922	1013.127	7.155	1017.128		
4.05	140.597	1011.050	7.086	1013.872		
5.05	139.724	1013.402	7.003	1017.773		
6.05	141.369	1020.928	6.957	1023.611		
7.05	141.345	1018.701	6.859	1020.812		
8.05	142.027	1015.027	6.808	1017.546		
9.05	D 2652.360	D 3118.797	D 1141.465	1011.390		
10.05	140.881	1006.004	6.691	1009.522		
11.05	140.395	1006.605	6.531	1010.788		
12.05	140.404	1005.578	6.815	1009.876		
13.05	139.382	1005.608	6.679	1009.136		
14.05	141.738	1006.839	6.548	1009.889		
15.05	142.542	1009.297	7.136	1012.042		
16.05	141.938	1006.093	7.113	1008.881		
17.05	142.562	1005.881	6.935	1007.940		
18.05	140.912	1005.059	6.947	1008.196		
19.05	144.785	1006.469	6.981	1009.961		
20.05	144.294	1004.339	6.907	1007.206		
21.05	143.726	999.590	6.867	1004.330		
22.05	97.745	999.851	6.857	1002.508		
23.05	94.108	997.774	6.322	1002.100		
24.05	62.589	1001.408	5.970	1004.017		
25.05	61.125	996.002	6.717	999.351		
26.05	60.473	1000.623	6.798	1002.688		
27.05	60.630	1002.664	6.561	1004.865		
28.05	95.041	1002.613	6.559	1005.250		
29.05	93.254	1003.553	6.623	1005.948		
30.05	106.595	1003.353	6.628	1005.785		
31.05	61.560	1001.121	6.069	1004.105		
min	60.473	996.002	5.970	999.351		
max	D 2652.360	D 3118.797	D 1141.465	1023.611		
MMV	202.453	1075.011	43.398	1010.023		
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						