

Menesine ataskaita: 06.2016



	UAB Fortum Klaipeda						sugeneruota: 1.07.2016
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.06	17.588	10.381	6.613	0.168	0.615	5.153	
2.06	17.498	10.572	7.308	0.468	0.570	5.368	
3.06	17.743	10.807	9.329	2.750	0.535	5.636	
4.06	17.502	10.536	8.267	3.867	0.546	5.687	
5.06	17.367	10.585	9.414	4.322	0.527	5.654	
6.06	17.034	10.395	9.062	1.441	0.526	5.541	
7.06	17.448	10.585	9.346	0.043	0.538	5.878	
8.06	17.458	10.488	8.552	1.526	0.576	5.716	
9.06	16.863	10.315	9.139	0.707	0.598	5.688	
10.06	17.879	10.481	11.815	0.504	0.558	6.730	
11.06	17.671	10.327	9.791	0.276	0.585	6.522	
12.06	16.134	9.448	10.100	0.975	0.723	6.582	
13.06	X	-	-	-	-	-	
14.06	-	-	-	-	-	-	
15.06	-	-	-	-	-	-	
16.06	-	-	-	-	-	-	
17.06	11.672	9.539	21.888	16.090	1.185	6.746	
18.06	15.548	9.426	4.076	1.832	0.763	5.266	
19.06	17.632	10.621	3.721	2.694	0.648	6.748	
20.06	16.867	10.277	5.179	3.591	0.604	6.630	
21.06	18.013	10.389	4.515	3.489	0.596	7.787	
22.06	17.876	10.619	5.730	2.548	0.550	7.032	
23.06	18.359	11.057	7.523	2.108	0.573	6.852	
24.06	18.187	10.537	5.905	2.413	0.649	6.967	
25.06	18.997	10.630	3.772	3.441	0.817	6.872	
26.06	18.483	10.429	4.888	5.686	0.831	5.515	
27.06	18.739	10.769	3.685	8.752	0.695	5.281	
28.06	18.760	10.987	4.212	5.956	0.577	5.436	
29.06	17.300	10.529	5.165	4.494	0.555	5.268	
30.06	17.406	10.472	4.772	2.834	0.549	6.453	
min	11.672	9.426	3.685	0.043	0.526	5.153	
max	18.997	11.057	21.888	16.090	1.185	7.787	
MMV	17.419	10.452	7.112	2.903	0.622	6.100	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 06.2016



	UAB Fortum Klaipeda						sugeneruota: 1.07.2016
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.06	0.000	0.619	146.548	1.871	0.257	156288.95	
2.06	0.000	0.620	148.199	1.827	0.121	159158.96	
3.06	0.000	0.675	151.755	1.942	0.108	159603.40	
4.06	0.000	0.737	155.288	1.935	0.171	162563.78	
5.06	0.001	0.824	155.982	2.056	0.128	167137.39	
6.06	0.002	0.794	151.673	1.984	0.042	167450.07	
7.06	0.003	0.749	152.220	1.909	0.177	169022.67	
8.06	0.001	0.726	155.374	2.044	0.134	170328.85	
9.06	0.001	0.724	148.942	1.882	0.150	167393.12	
10.06	0.001	0.681	146.759	1.836	0.163	170145.78	
11.06	0.002	0.692	148.585	1.998	0.155	170577.79	
12.06	0.001	0.879	147.543	2.195	0.128	153659.25	
13.06	-	-	-	-	-	102302.63	
14.06	-	-	-	-	-	3990.407	
15.06	-	-	-	-	-	1010.134	
16.06	-	-	-	-	-	1337.123	
17.06	0.003	0.019	140.038	0.446	0.111	94510.930	
18.06	0.002	0.007	142.012	0.493	0.091	167877.32	
19.06	0.001	0.009	155.018	0.602	0.110	171057.98	
20.06	0.000	0.039	156.211	0.618	0.099	168028.42	
21.06	0.000	0.025	155.631	0.616	0.097	172070.82	
22.06	0.000	0.006	156.714	0.601	0.156	169991.78	
23.06	0.000	0.113	154.251	0.606	0.153	169490.98	
24.06	0.000	0.000	154.281	0.584	0.127	162523.85	
25.06	0.000	0.000	156.258	0.622	0.140	163526.20	
26.06	0.000	0.003	155.454	0.621	0.197	165227.57	
27.06	0.000	0.000	156.664	0.746	0.117	173674.51	
28.06	0.000	0.000	159.029	0.620	0.124	175213.35	
29.06	0.000	0.000	153.842	0.568	0.116	172116.64	
30.06	0.000	0.000	149.189	0.523	0.132	171502.96	
min	0.000	0.000	140.038	0.446	0.042	1010.134	
max	0.003	0.879	159.029	2.195	0.257	175213.35	
MMV	0.001	0.350	152.346	1.237	0.135	146354.87	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 06.2016



UAB Fortum Klaipeda		sugeneruota: 1.07.2016				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.06	141.228	1017.066	6.913	1013.884	1056.307	
2.06	140.877	1016.546	6.732	1013.848	1068.668	
3.06	141.674	1014.598	6.498	1011.395	1096.930	
4.06	141.398	1011.617	6.678	1010.562	1085.598	
5.06	141.501	1015.430	6.682	1014.382	1060.150	
6.06	141.119	1021.874	6.888	1020.674	1048.962	
7.06	140.728	1023.962	6.703	1021.732	1071.154	
8.06	141.391	1014.898	6.775	1012.211	1044.245	
9.06	140.667	1012.913	6.914	1011.317	1041.702	
10.06	142.224	1004.739	6.642	1002.962	1043.272	
11.06	141.949	1006.638	6.819	1005.149	1018.012	
12.06	139.824	1013.238	8.187	1010.514	993.683	
13.06	X	X	X	X	-	
14.06	-	-	-	-	-	
15.06	-	-	-	-	-	
16.06	-	-	-	-	-	
17.06	108.293	1000.393	9.964	997.089	956.804	
18.06	136.710	1006.313	7.428	1004.456	999.024	
19.06	141.967	1020.121	6.678	1016.502	1069.169	
20.06	141.958	1020.714	7.113	1018.474	1044.491	
21.06	143.527	1018.126	6.829	1015.518	1037.754	
22.06	143.268	1025.044	6.736	1022.042	1041.461	
23.06	144.297	1027.663	6.381	1023.378	1066.189	
24.06	143.212	1022.816	6.808	1018.704	1037.456	
25.06	144.692	1017.481	6.682	1013.431	1026.441	
26.06	144.707	1012.281	6.803	1009.800	1040.414	
27.06	145.420	1015.091	6.548	1012.431	1046.901	
28.06	144.893	1016.695	6.314	1013.270	1063.370	
29.06	141.963	1015.117	6.730	1011.587	1051.966	
30.06	142.383	1015.075	6.608	1011.550	1062.105	
min	108.293	1000.393	6.314	997.089	956.804	
max	145.420	1027.663	9.964	1023.378	1096.930	
MMV	140.989	1015.701	6.912	1013.031	1047.201	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						