

Menesine ataskaita: 07.2017



UAB Fortum Klaipeda		sugeneruota: 1.08.2017				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.07	18.007	17.895	2.380	8.131	0.000	5.400
2.07	18.067	17.864	1.844	11.068	0.000	5.494
3.07	17.480	18.090	2.527	9.564	0.000	5.594
4.07	18.581	19.131	2.993	9.355	0.000	6.028
5.07	18.540	18.825	3.184	9.159	0.000	6.367
6.07	18.659	18.567	3.315	7.795	0.000	6.682
7.07	18.063	18.113	3.373	4.989	0.000	6.895
8.07	18.693	18.293	4.273	5.642	0.000	7.946
9.07	19.030	18.273	4.111	6.853	0.000	6.722
10.07	18.285	18.104	4.282	8.553	0.018	5.708
11.07	17.517	17.874	4.608	3.562	0.000	6.038
12.07	18.379	18.109	3.076	11.659	0.000	7.065
13.07	18.563	18.237	3.893	30.765	0.028	5.989
14.07	19.743	18.536	4.164	30.744	0.019	6.440
15.07	19.377	18.607	3.444	20.509	0.069	5.620
16.07	19.995	18.633	3.854	21.780	0.017	6.229
17.07	19.270	17.672	4.028	16.283	0.146	5.328
18.07	18.921	18.359	3.095	23.425	0.099	6.116
19.07	19.419	18.333	3.070	13.849	0.011	5.559
20.07	19.086	18.518	3.927	19.379	0.004	5.740
21.07	18.259	18.249	2.905	14.660	0.412	6.686
22.07	19.203	18.653	4.394	23.277	0.089	6.584
23.07	18.905	18.633	3.865	27.165	0.006	6.007
24.07	18.758	18.425	3.786	19.590	0.000	5.135
25.07	18.986	18.701	3.610	17.533	0.002	5.566
26.07	17.528	17.933	2.910	6.540	0.010	4.307
27.07	17.716	18.000	2.377	13.542	0.000	5.708
28.07	19.111	18.511	2.971	8.802	0.000	5.818
29.07	19.492	18.476	3.552	9.228	0.001	5.485
30.07	19.220	18.356	3.118	5.647	0.000	5.391
31.07	19.684	18.466	1.933	12.529	0.000	5.582
min	17.480	17.672	1.844	3.562	0.000	4.307
max	19.995	19.131	4.608	30.765	0.412	7.946
MMV	18.726	18.337	3.386	13.927	0.028	5.971
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2017



UAB Fortum Klaipeda		sugeneruota: 1.08.2017				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.07	0.082	0.186	180.229	0.494	0.803	216839.01
2.07	0.082	0.193	183.914	0.553	0.687	217960.37
3.07	0.081	0.166	192.081	0.443	0.716	215012.10
4.07	0.079	0.152	176.491	0.433	0.729	215466.17
5.07	0.080	0.209	178.219	0.533	0.712	220224.51
6.07	0.081	0.158	177.331	0.507	0.799	222076.95
7.07	0.082	0.110	178.018	0.420	0.745	219646.43
8.07	0.081	0.165	180.287	0.439	0.721	223615.64
9.07	0.081	0.179	186.872	0.517	0.684	223752.70
10.07	0.081	0.160	179.877	0.517	0.675	222595.73
11.07	0.081	0.177	178.836	0.533	0.707	219732.29
12.07	0.081	0.176	186.566	0.567	0.652	223220.79
13.07	0.081	0.210	183.982	0.604	0.806	224282.39
14.07	0.081	0.131	191.982	0.471	0.861	225533.82
15.07	0.081	0.157	180.928	0.414	0.684	225203.73
16.07	0.081	0.173	180.513	0.533	0.693	227130.17
17.07	0.083	0.219	182.507	0.546	0.835	226796.82
18.07	0.081	0.203	182.886	0.583	0.667	222311.62
19.07	0.081	0.211	181.334	0.511	0.727	224533.18
20.07	0.081	0.191	177.695	0.521	0.902	222607.31
21.07	0.081	0.151	193.027	0.481	0.753	196875.18
22.07	0.081	0.196	183.921	0.526	0.773	225078.93
23.07	0.081	0.213	186.933	0.587	0.776	224691.79
24.07	0.081	0.203	187.613	0.577	0.822	223177.93
25.07	0.080	0.196	192.180	0.565	0.649	223068.95
26.07	0.080	0.201	174.166	0.514	0.797	219294.56
27.07	0.081	0.224	179.879	0.577	0.715	220467.29
28.07	0.081	0.146	184.563	0.511	0.754	216591.82
29.07	0.080	0.147	178.084	0.595	0.630	224524.51
30.07	0.080	0.181	178.947	0.586	0.770	222480.04
31.07	0.081	0.214	180.763	0.624	0.809	221699.89
min	0.079	0.110	174.166	0.414	0.630	196875.18
max	0.083	0.224	193.027	0.624	0.902	227130.17
MMV	0.081	0.181	182.543	0.526	0.744	221177.07
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2017



	UAB Fortum Klaipeda			sugeneruota: 1.08.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.07	142.219	999.056	5.767	994.489	1072.910	2.382
2.07	142.639	1005.359	5.769	999.645	1110.856	1.811
3.07	141.549	1013.542	5.785	1008.125	1112.139	2.528
4.07	143.037	1013.761	5.108	1008.024	1056.281	3.001
5.07	143.774	1018.839	5.400	1011.987	1080.514	3.190
6.07	144.449	1021.411	5.552	1015.138	1062.276	3.319
7.07	142.903	1022.020	5.732	1015.307	1059.545	3.370
8.07	144.295	1016.094	5.543	1009.943	1045.930	4.277
9.07	145.143	1015.394	5.485	1009.626	1052.118	4.104
10.07	143.962	1018.149	5.615	1010.748	1046.907	4.286
11.07	142.191	1009.289	5.742	1003.743	1048.893	4.619
12.07	143.329	1011.548	5.588	1005.156	1069.390	3.079
13.07	143.351	1010.645	5.477	1005.000	1042.566	3.896
14.07	146.152	1017.990	5.293	1011.459	1045.083	4.152
15.07	145.306	1021.144	5.347	1014.658	1044.344	3.445
16.07	146.695	1023.155	5.196	1016.635	1055.913	3.857
17.07	145.267	1018.186	5.684	1012.390	1026.544	4.041
18.07	144.213	1021.037	5.417	1015.082	1047.910	3.099
19.07	145.545	1022.943	5.411	1015.890	1068.784	3.074
20.07	144.798	1018.894	5.344	1012.643	1055.512	3.932
21.07	143.915	1019.657	6.123	1013.434	1055.214	3.151
22.07	145.120	1022.533	5.368	1016.053	1058.677	4.409
23.07	144.723	1021.026	5.379	1014.338	1064.219	3.867
24.07	143.900	1013.301	5.370	1006.966	1059.499	3.795
25.07	144.626	1009.283	5.227	1003.125	1047.634	3.618
26.07	141.960	1003.510	5.529	997.602	1050.798	2.920
27.07	142.459	1006.856	5.527	999.821	1076.598	2.382
28.07	144.876	1011.039	5.233	1004.499	1068.478	X
29.07	145.775	1016.720	5.178	1010.094	1060.212	3.560
30.07	145.234	1017.919	5.200	1009.998	1066.578	3.108
31.07	145.424	1017.270	5.130	1011.204	1082.241	1.927
min	141.549	999.056	5.108	994.489	1026.544	1.811
max	146.695	1023.155	6.123	1016.635	1112.139	4.619
MMV	144.156	1015.405	5.468	1009.125	1061.139	3.393
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2017



	UAB Fortum Klaipeda						sugeneruota: 1.08.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.07	8.131	5.400	0.082	180.229	0.494	0.803	
2.07	11.068	5.494	0.082	183.914	0.553	0.687	
3.07	9.564	5.594	0.081	192.081	0.443	0.716	
4.07	9.355	6.028	0.079	176.491	0.433	0.729	
5.07	9.159	6.367	0.080	178.219	0.533	0.712	
6.07	7.795	6.682	0.081	177.331	0.507	0.799	
7.07	4.989	6.895	0.082	178.018	0.420	0.745	
8.07	5.642	7.946	0.081	180.287	0.439	0.721	
9.07	6.853	6.722	0.081	186.872	0.517	0.684	
10.07	8.553	5.708	0.081	179.877	0.517	0.675	
11.07	3.562	6.038	0.081	178.836	0.533	0.707	
12.07	11.659	7.065	0.081	186.566	0.567	0.652	
13.07	30.765	5.989	0.081	183.982	0.604	0.806	
14.07	30.744	6.440	0.081	191.982	0.471	0.861	
15.07	20.509	5.620	0.081	180.928	0.414	0.684	
16.07	21.780	6.229	0.081	180.513	0.533	0.693	
17.07	16.283	5.328	0.083	182.507	0.546	0.835	
18.07	23.425	6.116	0.081	182.886	0.583	0.667	
19.07	13.849	5.559	0.081	181.334	0.511	0.727	
20.07	19.379	5.740	0.081	177.695	0.521	0.902	
21.07	14.660	6.686	0.081	193.027	0.481	0.753	
22.07	23.277	6.584	0.081	183.921	0.526	0.773	
23.07	27.165	6.007	0.081	186.933	0.587	0.776	
24.07	19.590	5.135	0.081	187.613	0.577	0.822	
25.07	17.533	5.566	0.080	192.180	0.565	0.649	
26.07	6.540	4.307	0.080	174.166	0.514	0.797	
27.07	13.542	5.708	0.081	179.879	0.577	0.715	
28.07	8.802	5.818	0.081	184.563	0.511	0.754	
29.07	9.228	5.485	0.080	178.084	0.595	0.630	
30.07	5.647	5.391	0.080	178.947	0.586	0.770	
31.07	12.529	5.582	0.081	180.763	0.624	0.809	
min	3.562	4.307	0.079	174.166	0.414	0.630	
max	30.765	7.946	0.083	193.027	0.624	0.902	
MMV	13.927	5.971	0.081	182.543	0.526	0.744	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							