

Menesine ataskaita: 08.2017



	UAB Fortum Klaipeda						sugeneruota: 1.09.2017
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.08	19.427	18.671	3.106	21.174	0.000	5.740	
2.08	20.126	18.441	2.592	15.639	0.000	5.458	
3.08	19.110	18.236	2.873	18.167	0.006	5.322	
4.08	18.800	18.196	3.434	31.011	0.000	6.209	
5.08	20.324	18.548	2.713	14.868	0.001	5.418	
6.08	20.742	18.937	3.008	17.731	0.036	5.555	
7.08	20.238	18.733	2.977	20.487	0.158	5.111	
8.08	20.371	18.629	2.440	8.839	0.055	4.842	
9.08	20.596	19.146	4.343	10.785	0.137	5.091	
10.08	19.748	19.372	3.275	22.199	0.017	5.722	
11.08	20.185	19.261	3.753	13.591	0.031	5.489	
12.08	21.306	19.463	3.817	7.174	0.168	5.748	
13.08	20.340	19.013	2.858	15.042	0.064	5.683	
14.08	19.890	18.977	3.268	17.573	0.002	5.503	
15.08	19.942	19.248	3.224	13.141	0.000	5.461	
16.08	20.334	19.270	3.106	29.548	0.007	6.292	
17.08	19.534	19.132	3.069	16.530	0.023	5.292	
18.08	19.102	18.891	2.172	12.585	0.002	4.793	
19.08	20.293	19.205	2.834	19.439	0.000	5.817	
20.08	20.296	19.257	2.484	18.353	0.000	5.568	
21.08	20.169	19.157	2.671	20.213	0.002	5.723	
22.08	20.307	19.226	3.493	25.606	0.116	5.238	
23.08	20.650	19.262	3.517	8.261	0.073	5.172	
24.08	20.103	19.295	4.287	22.401	0.029	6.196	
25.08	20.412	19.365	3.151	12.459	0.012	5.760	
26.08	20.247	19.350	3.910	24.129	0.066	6.305	
27.08	19.825	19.125	3.273	24.264	0.061	5.842	
28.08	19.734	19.147	2.870	30.405	0.002	6.617	
29.08	20.804	19.120	7.351	30.561	0.063	6.586	
30.08	20.711	19.201	4.459	21.084	0.177	5.744	
31.08	19.668	15.606	4.372	11.994	0.007	5.429	
min	18.800	15.606	2.172	7.174	0.000	4.793	
max	21.306	19.463	7.351	31.011	0.177	6.617	
MMV	20.109	18.919	3.379	18.563	0.043	5.637	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 08.2017



	UAB Fortum Klaipeda sugeneruota: 1.09.2017					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.08	0.080	0.171	181.038	0.564	0.763	223591.06
2.08	0.081	0.160	192.284	0.593	0.689	223230.25
3.08	0.080	0.110	190.448	0.539	0.747	225071.20
4.08	0.080	0.091	186.791	0.467	0.738	221856.32
5.08	0.080	0.114	199.600	0.462	0.701	226472.00
6.08	0.080	0.126	197.064	0.457	0.668	226458.37
7.08	0.080	0.118	195.942	0.493	0.665	226774.73
8.08	0.081	0.083	D 211.028	0.484	0.674	228864.85
9.08	0.079	0.167	178.929	0.540	0.705	224592.70
10.08	0.078	0.155	167.708	0.547	0.743	221116.12
11.08	0.079	0.117	174.801	0.494	0.714	221985.17
12.08	0.079	0.127	171.444	0.555	0.650	226152.48
13.08	0.080	0.129	169.492	0.512	0.673	225184.92
14.08	0.079	0.147	172.170	0.531	0.715	224887.25
15.08	0.079	0.125	171.242	0.471	0.727	225580.37
16.08	0.079	0.153	176.190	0.499	0.707	226691.18
17.08	0.079	0.126	171.037	0.394	0.681	223773.20
18.08	0.079	0.095	170.301	0.317	0.734	220856.73
19.08	0.080	0.119	179.503	0.472	0.711	224486.31
20.08	0.079	0.103	176.026	0.410	0.723	225679.00
21.08	0.079	0.107	174.571	0.439	0.709	226943.43
22.08	0.078	0.107	174.591	0.359	0.731	228209.93
23.08	0.079	0.069	174.374	0.296	0.753	229085.12
24.08	0.078	0.104	172.374	0.440	0.818	227143.17
25.08	0.079	0.032	172.370	0.307	0.904	224598.79
26.08	0.079	0.070	172.916	0.416	0.781	226858.39
27.08	0.078	0.052	173.414	0.470	0.693	226334.42
28.08	0.078	0.071	181.721	0.470	0.704	226399.43
29.08	0.079	0.068	169.661	0.455	0.681	230886.93
30.08	0.079	0.102	169.089	0.474	0.719	230275.29
31.08	0.078	0.170	169.859	0.503	0.723	224129.51
min	0.078	0.032	167.708	0.296	0.650	220856.73
max	0.081	0.171	D 211.028	0.593	0.904	230886.93
MMV	0.079	0.113	178.633	0.465	0.721	225618.12
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2017



	UAB Fortum Klaipeda			sugeneruota: 1.09.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.08	145.322	1023.417	5.161	1015.864	1048.215	3.102
2.08	146.523	1017.939	5.219	1011.834	1071.614	X
3.08	145.070	1018.864	5.301	1011.486	1073.011	2.879
4.08	144.383	1010.796	5.298	1004.380	1052.233	3.424
5.08	147.082	1012.827	4.981	1006.684	1063.309	2.703
6.08	147.647	1018.224	4.790	1011.817	1071.218	3.015
7.08	147.015	1025.005	4.939	1018.319	1054.493	2.981
8.08	147.249	1028.405	5.006	1020.751	1043.868	2.444
9.08	147.152	1024.249	4.643	1016.969	1055.860	4.380
10.08	145.591	1022.303	4.598	1015.423	1080.816	3.263
11.08	147.045	1021.179	4.631	1013.867	1062.863	3.764
12.08	148.510	1014.661	4.453	1007.774	1055.872	3.815
13.08	146.580	1017.086	4.682	1011.021	1088.826	2.865
14.08	146.672	1027.243	4.806	1020.000	1075.428	3.246
15.08	146.499	1030.815	4.767	1023.497	1056.435	3.217
16.08	146.892	1025.628	4.675	1017.704	1068.787	3.119
17.08	145.912	1022.965	4.848	1016.612	1067.079	3.074
18.08	144.509	1020.573	4.871	1013.551	1102.536	2.201
19.08	146.495	1016.918	4.684	1009.998	1089.237	2.847
20.08	146.621	1022.258	4.634	1015.038	1074.987	2.484
21.08	146.990	1019.554	4.667	1012.540	1083.271	2.682
22.08	146.724	1018.095	4.623	1011.593	1061.210	3.501
23.08	147.567	1017.277	4.652	1010.841	1075.374	3.513
24.08	146.460	1016.848	4.608	1009.960	1075.650	4.299
25.08	146.427	1016.092	4.526	1009.625	1073.587	3.140
26.08	146.064	1020.529	4.581	1013.161	1074.061	3.919
27.08	145.154	1017.238	4.725	1010.578	1066.015	3.271
28.08	145.531	1020.933	4.692	1014.466	1076.502	2.880
29.08	147.151	1025.059	4.672	1017.534	1049.673	7.370
30.08	147.045	1021.100	4.621	1013.727	1062.367	4.466
31.08	145.136	1016.351	4.573	1009.343	1073.808	4.358
min	144.383	1010.796	4.453	1004.380	1043.868	2.201
max	148.510	1030.815	5.301	1023.497	1102.536	7.370
MMV	146.420	1020.337	4.771	1013.419	1068.652	3.382
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2017



	UAB Fortum Klaipeda						sugeneruota: 1.09.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.08	21.174	5.740	0.080	181.038	0.564	0.763	
2.08	15.639	5.458	0.081	192.284	0.593	0.689	
3.08	18.167	5.322	0.080	190.448	0.539	0.747	
4.08	31.011	6.209	0.080	186.791	0.467	0.738	
5.08	14.868	5.418	0.080	199.600	0.462	0.701	
6.08	17.731	5.555	0.080	197.064	0.457	0.668	
7.08	20.487	5.111	0.080	195.942	0.493	0.665	
8.08	8.839	4.842	0.081	D 211.028	0.484	0.674	
9.08	10.785	5.091	0.079	178.929	0.540	0.705	
10.08	22.199	5.722	0.078	167.708	0.547	0.743	
11.08	13.591	5.489	0.079	174.801	0.494	0.714	
12.08	7.174	5.748	0.079	171.444	0.555	0.650	
13.08	15.042	5.683	0.080	169.492	0.512	0.673	
14.08	17.573	5.503	0.079	172.170	0.531	0.715	
15.08	13.141	5.461	0.079	171.242	0.471	0.727	
16.08	29.548	6.292	0.079	176.190	0.499	0.707	
17.08	16.530	5.292	0.079	171.037	0.394	0.681	
18.08	12.585	4.793	0.079	170.301	0.317	0.734	
19.08	19.439	5.817	0.080	179.503	0.472	0.711	
20.08	18.353	5.568	0.079	176.026	0.410	0.723	
21.08	20.213	5.723	0.079	174.571	0.439	0.709	
22.08	25.606	5.238	0.078	174.591	0.359	0.731	
23.08	8.261	5.172	0.079	174.374	0.296	0.753	
24.08	22.401	6.196	0.078	172.374	0.440	0.818	
25.08	12.459	5.760	0.079	172.370	0.307	0.904	
26.08	24.129	6.305	0.079	172.916	0.416	0.781	
27.08	24.264	5.842	0.078	173.414	0.470	0.693	
28.08	30.405	6.617	0.078	181.721	0.470	0.704	
29.08	30.561	6.586	0.079	169.661	0.455	0.681	
30.08	21.084	5.744	0.079	169.089	0.474	0.719	
31.08	11.994	5.429	0.078	169.859	0.503	0.723	
min	7.174	4.793	0.078	167.708	0.296	0.650	
max	31.011	6.617	0.081	D 211.028	0.593	0.904	
MMV	18.563	5.637	0.079	178.633	0.465	0.721	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							